

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE OF PAGES 1 5	
2. AMENDMENT/MODIFICATION NO. 0006		3. EFFECTIVE DATE 03-Jul-2002		4. REQUISITION/PURCHASE REQ. NO. W16ROE-2114-9736		5. PROJECT NO.(If applicable)	
6. ISSUED BY CONTRACTING DIVISION US ARMY CORPS OF ENG, NYD ATTN: CENANCT, ROOM 1843 26 FEDERAL PLAZA NEW YORK NY 10278		CODE DACA51		7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. DACA51-02-B-0009	
				X		9B. DATED (SEE ITEM 11) 22-May-2002	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u> 1 </u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A.THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B.THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C.THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D.OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of Amendment 0005 to Solcitation DACA51-02-B-0009 is to amend and clarify the specifications and drawings in Sections 00800 and 00901, "Revitalize Barracks USMA Preparatory School Building 1204 and 1205, Fort Monmouth, Eatontown, New Jersey." NOTE: Bidders must acknowledge receipt of this amendment by the date specified in the solicitation (or as amended) by one of the following methods: in the space provided in the SF 1442, by separate letter, by telegram, or by signing Block 15 below. FAILURE TO ACKNOWLEDGE AMENDMENTS BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR BID IN ACCORDANCE WITH THE LATE BID, LATE MODIFICATIONS OF BIDS, OR LATE WITHDRAWAL OF BIDS (FAR 14.305). As a result of this amendment, the bid opening date is extended from 10 July 2002 @1:00 PM to 22 July 2002@ 1:00 PM.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)		03-Jul-2002	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Changes in Section 00800

NOTICE TO BIDDERS

Failure of the bidder to
Acknowledge receipt
Of this Amendment in
Item 19 of Standard
Form 1442 (Pg. 00010-2)
May result in REJECTION
Of the bid.

IFB NO. DACA51-02-B-0009

Amendment No. 6

Department of the Army, NYD
Corps of Engineers
New York, NY 10278-0090

AMENDMENT NO. 6 TO SPECIFICATIONS FOR REVITALIZE BARRACKS USMA PREPARATORY
SCHOOL BUILDINGS 1204 & 1205, FORT MONMOUTH, EATONTOWN, NEW JERSEY

TO BIDDERS

1. The following changes are made to the specifications and drawings.

CLARIFICATIONS TO AMENDMENT NO. 2:

- a. The wages rates are in Section 00900, not 00800 as referenced.
- b. Trailer locations and requirements are in Section 00901, not 00801 as referenced.
- c. Issued sketches refer to the drawings listed below:

Sketch SK-1 refers to drawings M-102 and M-103

SK-2 refers to drawing M-202

SK-3 refers to drawing M-203

SK-4 refers to drawing M-209

SK-5 refers to drawing M-210

SK-6 refers to drawing M-211

SK-7 refers to drawing M-212

SK-8 refers to drawing M-212

SK-9 refers to drawing M-213

SK-10 refers to drawing M-214

SK-11 refers to drawing M-215

SK-12 refers to all dryer exhaust installations

CLARIFICATIONS TO AMENDMENT NO. 3:

- a. Drawing M521 remains as part of the solicitation package. Drawing M531 is not used.
- b. The paragraph number of new paragraph ENTRANCE MATS added in Section 09650 should be 2.10 instead of 2.9.
- c. Item g under Section 09650 should be part of the drawing changes.

CLARIFICATIONS TO AMENDMENT NO. 5

- a. The 21 structural sketches (listed twice) and 1 additional sketch are on new drawing S-03 Structural Sketches and Details, issued in this amendment.
- b. The sketches showing revisions to Drawings FP-11, FP-15 and MP-26, which were inadvertently missing, are now included in the revised drawings issued in amendment No. 6.

SPECIFICATIONS

- a. Section 00800, add the following new paragraph:

“43. WALL-MOUNTED EQUIPMENT

The Contractor will be responsible for the moving and mounting of existing chalkboards, tackboards, project screens etc. to the temporary trailers, from their existing barracks locations and back to the renovated barracks. Exact wall locations in the renovated barracks will be coordinated with the Contracting Officer.”

- b. Section 0222A, add the following to the end of paragraph 3.4.2: “Combustible material shall be disposed of off the site. All material disposed of off-site shall be in accordance with Federal, State and local regulations.”

- c. Section 10500, add paragraph 3.4 as follows:

“3.4 Medium Voltage Cable and Transformer Test

After installation of the 5 KV cable and pad mounted transformer the Contractor shall perform a high potential test before termination of the cable at the overhead pole line. The tests shall be performed as required in specification Section 16375A paragraphs 3.11.5 and 3.11.7, respectively. The termination of the cable at the pole, installation of the fused cutouts and the pole top work will be performed by others. The same shall apply for the installation of 5 KV cables and transformers for the renovation of Buildings 1204 and 1205.”

- d. Section 16375A, add “and pressure gauge” in the 3rd sentence of paragraph 2.9.2.5.

DRAWINGS

The following drawings are issued:

- a. Revised: T-002, A-002, A-007, A-012, A-013, A-014, A-016, A-017, A-018, A-024, A-025, A-038, A-058, A-059, DE-101, E-111, E-112, E-202, E-205, E-206, FP-11, FP-15, MP-26 and DMP-3.
- b. New: S-03.

The following drawings are deleted: i-001, i-011 and i-025

RESPONSES TO BIDDERS' QUESTIONS (QUESTIONS AND ANSWERS ARE FOR INFORMATIONAL PURPOSES ONLY)

1. Specifications #00901 indicates 64 computers, as well as various equipment are they to be furnished by contractor? If so what is to happen to computers at end of contract?

Response: As indicated in Amendment No. 2: the Government (USMAPS) will supply all equipment within the trailers. The computers will be Government-furnished and Government-installed.

2. Revised drawing A-064 thru A-071 – Indicated ACT ceiling & Paint – Are these ceilings to be painted?

Response: New ACT will not be painted.

3. Spec 10650 Wire Mesh Partitions – no drawing indicates any wire mesh partitions. Where is it to be installed?

Response: See drawing A-008, Room 217.

4. The carpet specified on the finish schedule is Broadloom – but in several places (Dwg. A-033 & A-070) it calls for carpet tile. (there is no spec. for carpet tile) What carpet is required?

Response: All carpet tile. No Broadloom.

5. Where is outdoor carpet used?

Response: Not used.

6. Drawing A-100 thru A-105 – What does “MDH” stand for in remarks? Magnetic Door Holder?

Response: Yes.

2. This Amendment shall be attached to the specifications and shall become a part thereof.

Attached

ELLA D. SNELL
C, Contracting Division
Contracting Officer